




Richard Barrett
Chief

Millis Fire/Rescue

885 Main Street
Millis, Massachusetts 02054

Phone: 508-376-2361
Fax: 508-376-4339



TRANSFER TANK INSPECTION

(Not to exceed 119 Gallons capacity in pickup/utility trucks, etc.)

REGISTRATION# _____ VIN# _____

	YES	NO
Tank is a minimum 14 gauge steel or 1/8 inch aluminum		
Tank is securely mounted to bed or body of vehicle		
Suitable pump with durable hose and self-closing nozzle		
Fire extinguisher minimum 1A, 10B, C Rating		
Vehicle containing a hoist to raise bed or body (Prohibited)		

D.O.T PLACARDS ARE NOT REQUIRED

Inspected by: _____

Fire Department: _____

Permit # _____

Date: _____

Please retain this copy as proof of compliance